

STAINLESS STEEL TIE-DOWN INSTALLATION INSTRUCTIONS:

STEP 1:

INSTALL SUPPLIED STAINLESS STEEL BRACKETS TO MARKED LOCATIONS ON THE TANK AS PER DRAWING.
FIT SUPPLIED SHACKLE TO SUPPLIED STAINLESS STEEL BRACKET.

NOTE: TANKS (450L TO 10,000L WILL NOT HAVE STAINLESS STEEL BRACKETS, USE TANK MOLDED LIFTING POINTS TO MOUNT SHACKLE.

STEP 2:

ATTACH PRE-CUT WIRE ASSEMBLY TO SHACKLE.
NOTE: WIRE ASSEMBLY WILL COME PRE-CUT TO THE SIZE OF THE TANK PURCHASED.
ENSURE ALL WIRE ASSEMBLY ARE SAME LENGTHS.

STEP 3:


PULL WIRE ASSEMBLY OUT AT AN ANGLE TO LOCATE CONCRETE ANCHOR DRILL LOCATION.
DRILL MARKED LOCATION.
INSERT CONCRETE ANCHOR INTO DRILL LOCATION AND TIGHTEN. ENSURE YOU LEAVE ENOUGH THREAD EXPOSED ABOVE GROUND FOR SUPPLIED EYE NUT TO THREAD ON.


STEP 4:

PULL WIRE ASSEMBLY AND ATTACH TO GROUND ANCHOR USING EYE-NUT.

STEP 5:

REPEAT STEPS 1-4 FOR ALL ANCHORS.
ONCE INSTALLED, ENSURE ALL EYE-NUTS ARE TIGHTENED WITH 2-4 THREADS EXPOSED. ENSURE ALL WIRE ASSEMBLY TIGHTENED AND UNDER TENSION.



 Promax <small>LIQUID MANAGEMENT SOLUTIONS</small>	DO NOT SCALE DRAWING		ISSUED: 30/07/2024	DISPLAY NAME/NUMBER: Stainless Steel Tie Down INSTALLATION	
			AUTHOR:		
<small>PROPRIETARY AND CONFIDENTIAL</small> <small>THIS DRAWING AND THE INFORMATION AND TECHNICAL DATA CONTAINED HEREIN ARE THE EXCLUSIVE PROPERTY OF PROMAX PLASTICS AND SHALL BE RETURNED TO THEM UPON REQUEST.</small> <small>THIS DRAWING CONTAINS PROPRIETARY AND CONFIDENTIAL INFORMATION FOR THIS PROJECT AND IS NOT TO BE MADE AVAILABLE TO 3RD PARTIES WITHOUT THE EXPRESS WRITTEN CONSENT OF PROMAX PLASTICS</small>			MATERIAL:	DWG No.	A3
			WEIGHT: kg	SCALE: 1:50	